

PUBLIC NOTICE
IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Monitoring Requirements Not Met for Colfax Waterworks

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. Between 11/01/2019 and 11/30/2019, we did not monitor for coliform bacteria, and therefore cannot be sure of the quality of your drinking water during that time.

What precautions should be taken at this time?

There are no special precautions you need to take at this time. However, it is important to remember that the quality of your drinking water during that period is not known at this time.

What was the cause of the missed monitoring requirements?

One of two required coliform bacteria water samples was missed during the month of November.

What is being done to correct the problem?

All Public Works employees will have access to a chart which will indicate that the required coliform bacteria samples have been completed by the 15th and the last day of each month.

When will the problem be resolved?

There has already been a required coliform bacteria test completed on December 3, 2019, which indicated safe coliform bacteria results.

If you have questions regarding the safety of our drinking water, please contact:

Rand Bates, Director of Public Works
614 Railroad Ave., Colfax, WI 54730
715-962-4441

I certify that the information and statements contained in this public notice are true and correct and have been provided to consumers in accordance with the delivery, content, format, and deadline requirements in subchapter VII of ch. NR 809, Wis. Adm. Code.

X *Lynn M. Niggemann*

Signature

12/11/2019

Date

** Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place distributing copies by hand or mail.